

DELHI DEVELOPMENT AUTHORITY
OFFICE OF THE EXECUTIVE ENGINEER (E)
ELECTRICAL DIVISION-5, DWARKA,
NEW DELHI-110045

No. EE/ED-5/DDA/W-30/737
Minutes of Meeting

Dated: 13/4/16

Subject:- Pre-bid meeting.

NIT-101/EE/ELD-5/DDA/15-16

Name of work:- C/o Community room at Bindapur, Pkt-III.

SH: Providing & Installation of wet riser for fire fighting system water supply pump, fire extinguishers.

NIT-102/EE/ELD-5/DDA/15-16

Name of work:- C/o community hall cum-function site at village Dhulsiras and joining sector-24, Dwarka, Ph-II.

SH: Providing & Installation of wet riser for fire fighting system water supply pump, fire extinguishers.

Pre bid meeting was held in the office of Executive Engineer (Elect.), Electrical Division No.5 on 12.04.2016 at 11:00 AM. Meeting was attended by the following officers of DDA & bidders.

DDA

1. Sh. Naveen Walia, EE (E), ELD-5
2. Sh. S.C. Yadav, AE (E)/ELD-5
3. Sh. Ashok Kumar, JE (E)/ELD-5

Bidders

1. M/s Fire Cool Engineers (Mr. Sarabjeet Singh, Manager)

After due discussion and deliberations, following changes/modifications/additions/ clarifications are made.


Reference	Existing Provision	Modified Provision
(A) Schedule of Items		
Items No. 4	The terrace pump is multi stage and split casing type	The terrace pump shall be mono block type
Item No.5	Domestic water pump with motor	The domestic water pump shall be mono block type
Item No.11	Providing & fixing of stainless steel fire service inlet in order to facilitate feeding of water in the system by fire tender with 100 mm N.B. Flanged inlet, brass spindle, two nos. 63 mm dia male/female instantaneous outlet type S.S. coupling, blank cap, chain, conforming to IS :5290. including tapping from wet riser complete required.	Supplying & fixing 3 way fire brigade connection of CI body with three stainless steel male instantaneous inlet coupling complete with cap and chain as required for 100 mm dia M.S. pipe connection conforming to IS:904 as required.
Item No.12	Supplying and fixing stainless steel single headed landing valve for internal hydrant with 1 No. 63mm dia instantaneous female-male S.S coupling and cast iron wheel ISI marked conforming to IS : 5290 (Type A) with blank ABS cap & chain i/c 6mm thick SS orifice plate of reqd. size as reqd.	Supplying and fixing stainless steel single headed landing valve for internal hydrant with 1 No. 63mm dia instantaneous S.S coupling and cast iron wheel ISI marked conforming to IS : 5290 (Type A) with blank ABS cap & chain as reqd.

Item No.34	Providing and fixing C.I.'Y' strainer with bronze perforated sheet basket tested to a pressure of 15 kg/sq.cm including rubber gasket, flanges, nuts, bolts and washer, complete as required. a) 80 mm dia b) 200 mm dia	Providing and fixing C.I.'Y' strainer with S.S. perforated sheet basket tested to a pressure of 15 kg/sq.cm including rubber gasket, flanges, nuts, bolts and washer, complete as required. a) 80 mm dia b) 200 mm dia
(B) List of acceptable makes S. No.		
4) Butterfly Valve(IS:130 95)	AUDCO/ Kirloskar / IVC	AUDCO/ Kirloskar / IVC/ Kartar/ Castle/ Getech
7) MS / G.I Pipe Fitting	R-Brand / UNIX	i) M.S. fittings—shall be fabricated type. ii)G.I. fittings -- R-Brand / UNIK/Zoloto/DRP
8) Steel Pipe Flange (IS:6392)	AUDCO/ C&R	Makes Deleted
25) Fire Extinguisher (ISI 15683)	Minimax / Cease Fire	Minimax / Cease Fire/ Omax/ Suprex/ Getech
32) LT Panel	ADVANCE PANELS & SWITCHGEARS (P) LTD./ TRICOLITE / ASSOCIATED SWITCH GEAR & PROJECTS .LTD.(ASPL) / ADLEC SYSTEMS PVT. LTD / MILESTONE / AMBIT	ADVANCE PANELS & SWITCHGEARS (P) LTD./ TRICOLITE / ASSOCIATED SWITCH GEAR & PROJECTS .LTD.(ASPL) / ADLEC SYSTEMS PVT. LTD / MILESTONE / AMBIT/ Risha/SPC electrotech. Note: The panel shall be CPRI approved.

General:


1. Date of submission of e-tender shall be modified as **21.04.2016** and financial bid shall be opened on **27.04.2016**.
2. The department shall have the right to insist upon computerized billing, measurement through mobile application etc. to which the bidder should not have any objection.
3. All the order of Hon'ble NGT made up to date (if any) shall also be complied with.

This letter shall form part of the tender. Therefore, this letter duly stamped and signed by the tenderers in lieu of their acceptance, shall be submitted by all the tenderers failing which their tenders will not be opened.


AE (E)-IV



JE (E)


AE (E) Plg./D-Man


EE (E)/ELD-5

Copy to:

1. SE (E)/EC-I/DDA, for information please.
2. EE (E)Plg./EC-I, for information please.


EE (E)/ELD-5